DRG No. PX10484-1	REMOVE BURRS AND SHARP EDGES	IF IN DOUBT ASK	DO NOT SCALE	THIRD ANGLE PROJECTION

PUMP SIZE	MOTOR KW	FLC AMPS 3x415V	PUMP WEIGHT KGS	SET WEIGHT KGS	VESSEL SIZE LITRES	WORKING PRESSURE MAX. BAR	TEST PRESSURE BAR
6601/1F40T	4.00	8.02	89	1345	60	10	15
6601F55T	5.50	10.0	107	1435	60	10	15
6602/2F75T	7.50	13.4	118	1490	60	10	15

ALL FLANGES TO BS4504 16BAR

UNCONTROLLED



ANTI-VIBRATION MOUNTINGS OPTIONAL ONLY SUPPLIER WHEN ORDERED (6-PER SET K2092/10)



FLEXIBLE CONNECTORS OPTIONAL ONLY SUPPLIED WHEN ORDERED (2-PER SET)

NOTE :-

1) MAIN POWER SUPPLY TO PANEL MUST BE SIZED TO COVER ALL PUMP RUNNING AT SAME TIME

2) LARGE STORAGE VESSELS,IF ORDERED,WILL BE SUPPLIED LOOSE FOR POSITIONING BY CLIENT TO SUIT THE AVAILABLE FLOOR SPACE. CLIENT IS TO PROVIDE A CONNECTION FROM THE VESSEL TO THE DELIVERY PIPEWORK ADJACENT TO THE SET ISOLATING AND DRAIN VALVES SHOULD BE FITTED IN THIS CONNECTION





LAST MODIFICATION DETAILS		
DRAWING BORDER CHANGED		
ISSUE	DATE15/02/2006	DRN PJB
1	CHK PJB	APP PJB

ALL DIMENSIONS IN mm
DRAWN TO BS308
WELDING SYMBOLS TO BS499
SURFACE FINISH SHOWN IN MICROMETERS
MACHINE WHERE SHOWN ∀
TO TOLERANCE ± 0.3MM
UNLESS OTHERWISE STATED

JOB No.	PART No.	WEIGHT KG	FILE NAME
-	-	-	px10484-1
DESIGN No.	PATTERN No.	MATERIAL	MAT'L SPEC.
-	-	-	-

THIS DRAWING IS THE PRIVATE AND CONFIDENTIAL PROPERTY OF ARMSTRONG HOLDEN BROOKE PULLEN LTD. ALL COPYRIGHT, MANUFACTURING AND SALES RIGHTS RESERVED.

TITLE
GENERAL ARRANGEMENT
HYDROPAK IVSL5 SET
66-PUMP MODELS C/W
VLT8000 AQUA CONTROL

DRG No. PX10484-1	
DATE19/08/2004	DRN BSD
CHK EGJ	APP EGJ
SCALE NTS	SHEET 1 OF 1

ARMSTRONG HOLDEN BROOKE PULLEN
WENLOCK WAY, MANCHESTER. M12 5JL
TEL: +44 (0) 161 223 2223