



EXCHANGER SIZE *BAFFLE SPACING	DIMENSIONS											
	A		B		C		D		N1		N2	
	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm
W-63-2*-4	47 5/8	1210	28	711	19	483	37	940	3	76	3	76
W-64-2*-4	59 5/8	1514	40	1016	31	787	49	1245	3	76	3	76
W-65-2*-4	71 5/8	1819	52	1321	43	1092	61	1549	3	76	3	76
W-66-2*-4	83 5/8	2124	64	1626	55	1397	73	1854	3	76	3	76
W-67-2*-4	95 5/8	2429	76	1930	67	1702	85	2159	3	76	3	76
W-68-2*-4	107 5/8	2734	88	2235	79	2007	97	2464	3	76	3	76
W-69-2*-4	119 5/8	3038	100	2540	91	2311	109	2769	3	76	3	76
W-610-2*-4	131 5/8	3343	112	2845	103	2616	121	3073	3	76	3	76
W-611-2*-4	143 5/8	3648	124	3150	115	2921	133	3378	3	76	3	76
W-612-2*-4	155 5/8	3953	136	3454	127	3226	145	3683	3	76	3	76

NOZZLE SCHEDULE				
SERVICE	MARK	SHELL SIDE	MARK	TUBE SIDE
INLET	(N1)	AS PER TABLE	(N5)	2 (51) FLG
OUTLET	(N2)	AS PER TABLE	(N6)	2 (51) FLG
DRAIN	(N3)	1/2 (13) NPT		
VENT	(N4)	3/4 (19) NPT		

NOTES: 1. SUPPORTS SUPPLIED ONLY IF SPECIFIED ON ORDER.
 2. NOZZLE SIZES SHOWN ARE RECOMMENDED FOR MAXIMUM EXCHANGER LIFE.
 3. FABRICATED TO ASME CODE SECTION VIII DIVISION 1 AND LATEST ADDENDA.
 4. DRAWING IS NOT TO SCALE.
 5. ALL DIMN'S ±1/8 (3) UNLESS OTHERWISE SHOWN.

DESIGN CONDITIONS				
	SHELL		TUBES	
DESIGN PRESSURE	150 PSIG	1034 KP ₀	150 PSIG	1034 KP ₀
DESIGN TEMPERATURE	375 °F	191 °C	375 °F	191 °C
MIN. DESIGN METAL TEMP.	35 °F	1.7 °C	35 °F	1.7 °C
HYDRO. TEST PRESSURE	225 PSIG	1551 KP ₀	225 PSIG	1551 KP ₀
CONTENTS	WATER		WATER	

CUSTOMER:
 LOCATION:
 ENGINEER:
 ORDER No.:
 PROJECT/JOB:
 LOCATION:
 TAG: (QUOTE #)

TITLE	G.A. 150 LB. W SERIES HEAT EXCHANGERS				A R M S T R O N G				NUMBER	REV.			
DATE:	12 / 01 / 94	BY:	D.C.R.	TEL :	(416) 755-2291	TEL :	(514) 421-2424	TEL:	(716) 693-8813	TEL:	(44) 120-657-9491	W-6-2P-4(3)	